

Certificate of Conformity (COC)



Certificate Holder : NINGBO DEYE ESS TECHNOLOGY CO., LTD
No.568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang,
China

Manufacturer's Name : NINGBO DEYE ESS TECHNOLOGY CO., LTD
No.568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang,
China

and address

Date of Original Issue : 06/01/2025

Date of Last Revision : -

Date of Expiry : 05/01/2028

Certificate Number : PCS-24-20023

Product : Lithium-ion Rechargeable Battery System

Ratings : See page 2

Brand : **Deye**

Model : BOS-A50, BOS-A60, BOS-A65, BOS-A75, BOS-A80, BOS-A90, BOS-A95, BOS-A105, BOS-A115,
BOS-A120, BOS-A130, BOS-A135, BOS-A145, BOS-A150, BOS-A160

Test Laboratory: SGS-CSTC Standards Technical Services Co., Ltd. Shenzhen Branch


Testing Report(s): SZES240800607301

Test Standard(s): VDE-AR-E 2510-50:2017-05

This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).

Jerry Xiao
Certification Officer

SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way #03-01 Singapore 609957



Ratings :

BOS-A50: 268.8 V d.c., 200 Ah, BOS-A60: 307.2 V d.c., 200 Ah, BOS-A65: 345.6 V d.c., 200 Ah,
 BOS-A75: 384 V d.c., 200 Ah, BOS-A80: 422.4 V d.c., 200 Ah, BOS-A90: 460.8 V d.c., 200 Ah,
 BOS-A95: 499.2 V d.c., 200 Ah, BOS-A105: 537.6 V d.c., 200 Ah, BOS-A115: 576 V d.c., 200 Ah,
 BOS-A120: 614.4 V d.c., 200 Ah, BOS-A130: 652.8 V d.c., 200 Ah, BOS-A135: 691.2 V d.c., 200 Ah,
 BOS-A145: 729.6 V d.c., 200 Ah, BOS-A150: 768 V d.c., 200 Ah, BOS-A160: 806.4 V d.c., 200 Ah

